

ADDENDUM ORDER

ORDER NO. 5
DATE: June 24, 2016
BID DATE: June 29, 2016

NAME OF PROJECT: Grand Avenue Pedestrian Bridge

OWNER: City of Glenwood Springs

ENGINEER: SGM and Pattillo Associates Engineers

Please be aware that previous Addenda listed an erroneous Bid Date of June 28, 2016. In accordance with the Bid Documents, Invitation to Bid, “sealed bids... will be received at the City... until 2:00 p.m. (MDST) Wednesday, June 29th, 2016, at which time they will be publicly opened and read aloud.”

The following changes are hereby made to the CONTRACT DOCUMENTS:

The following question was not addressed in previous addenda:

- 1. Will the sleeving for the irrigation need to be bored or will we be laying the irrigation down prior to construction of hardscapes?

ANSWER: Irrigation sleeving shall be installed prior to installing hardscape.

ADDENDUM ACKNOWLEDGED BY:

Name

Date

PREPARED BY:

Robert Pattillo, P.E.,
Pattillo Associates Engineers, Inc.

List of Attachments:

NONE