



New waterline to be installed here (to loop between Tanager Dr. and Ptarmigan Dr.)

A pressure zone break runs along Ptarmigan Dr. PRV station(s) may need to be installed at one or more sites in these approximate locations.

Waterlines shown within balloon boundary to be replaced (boundary is approximate)

Possible relocation of this waterline (to run within Cardinal Ln. and tie-in at intersection with Ptarmigan Dr.)

This waterline may need to be relocated due to accessibility issues.



New waterline to be installed here (to loop between Tanager Dr. and Ptarmigan Dr.)

A pressure zone break runs along Ptarmigan Dr. PRV station(s) may need to be installed at one or more sites in these approximate locations.

Waterlines shown within balloon boundary to be replaced (boundary is approximate)

Possible relocation of this waterline (to run within Cardinal Ln. and tie-in at intersection with Ptarmigan Dr.)

This waterline may need to be relocated due to accessibility issues.

